

**ROCHESTER REGIONAL BOARD OF REVIEW
MEETING MINUTES
JULY 12, 2023**

FIRST HEARING

IN THE MATTER OF PETITION NO. 2023-0307

THE PETITIONER IS: JAMES & LISA BUETTNER

- MOTION: GRANTED WITH CONDITIONS BY JOHN LIMBECK
- SECOND: CRAIG JENSEN
- RELIEF FROM: **19 NYCRR, Part 1225, The Fire Code of New York State, Section 507.5.1, Exception #1** which reads that the maximum distance from a building to a hydrant shall be less than 600 feet for a Group R-3 Occupancy.
The single-family dwelling is 718 feet from the nearest hydrant.

Vote:

AYE JAMES BURTON, CHAIRMAN
NAY MARK CAVANAUGH
AYE JOHN LIMBECK
NAY RICK PAPAJ
AYE CRAIG JENSEN

SECOND HEARING

IN THE MATTER OF PETITION NO. 2023-0292

THE PETITIONER IS: EMPIRE COMMERCIAL CONSTRUCTION

- MOTION: ADJOURNED BY MARK CAVANAUGH
- SECOND: RICK PAPAJ

Vote:

AYE JAMES BURTON, CHAIRMAN
AYE MARK CAVANAUGH
AYE JOHN LIMBECK
AYE RICK PAPAJ
AYE CRAIG JENSEN

